



Water - Essential for Life

# City of Sebree Water Department

## Water Quality Report for year 2014

KY1170388

P.O. Box 245 Sebree, Kentucky 42455		
Meetings:	City Hall 36 S. Spring Street	
Meeting Dates and Time:	The first Monday of each month	5:00 PM

Manager:	<b>Emery Thomas</b>
Phone:	<b>(270) 835-7501</b>
CCR Contact:	<b>Emery Thomas</b>
Phone:	<b>(270) 835-7501</b>

This report is designed to inform the public about the quality of water and services provided on a daily basis. Our commitment is to provide our customers with a safe, clean, and reliable supply of drinking water. We want to assure that we will continue to monitor, improve, and protect the water system and deliver a high quality product. Water is the most indispensable product in every home and we ask everyone to be conservative and help us in our efforts to protect the water source and the water system. The source of your drinking water is surface water from the Green River, located at approximately river mile marker 41.3 or 9000 Hwy 2096 in Robards, Kentucky. The area around your water source is mostly residential, but contains some industry, and, agricultural. The final source water assessment of this system has been completed and is contained in the Main office of Henderson Water Utility, Henderson County Water District, or at the Green River Area Development District office in Owensboro, Kentucky. An analysis of the susceptibility of Henderson's Ohio River and Green River water supplies to contamination indicates that this susceptibility is generally moderate. However, there are a few areas of high concern. Concerns include beidges, waste generators or transporters, landfills, river ports, a railroad, row crop land coverage, urban and recreational grass coverage and sewer lines.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects may be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and may pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants, such as viruses and bacteria, (sewage plants, septic systems, livestock operations, or wildlife). Inorganic contaminants, such as salts and metals, (naturally occurring or from stormwater runoff, wastewater discharges, oil and gas production, mining, or farming). Pesticides and herbicides, (stormwater runoff, agriculture or residential uses). Organic chemical contaminants, including synthetic and volatile organic chemicals, (by-products of industrial processes and petroleum production, or from gas stations, stormwater runoff, or septic systems). Radioactive contaminants, (naturally occurring or from oil and gas production or mining activities).

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water to provide the same protection for public health.

***Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).***

**Some or all of these definitions may be found in this report:**

**Maximum Contaminant Level (MCL)** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Below Detection Levels (BDL)** - laboratory analysis indicates that the contaminant is not present.

**Not Applicable (N/A)** - does not apply.

**Parts per million (ppm)** - or milligrams per liter, (mg/l). One part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb)** - or micrograms per liter, (µg/L). One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

**Parts per quadrillion (ppq)** - one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

**Picocuries per liter (pCi/L)** - a measure of the radioactivity in water.

**Millirems per year (mrem/yr)** - measure of radiation absorbed by the body.

**Million Fibers per Liter (MFL)** - a measure of the presence of asbestos fibers that are longer than 10 micrometers.

**Nephelometric Turbidity Unit (NTU)** - a measure of the clarity of water. Turbidity has no health effects. However, turbidity can provide a medium for microbial growth. Turbidity is monitored because it is a good indicator of the effectiveness of the filtration system.

**Variances & Exemptions (V&E)** - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system shall follow.

**Treatment Technique (TT)** - a required process intended to reduce the level of a contaminant in drinking water.

### Information About Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your local public water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

**Spanish (Español)** Este informe contiene información muy importante sobre la calidad de su agua beber. Tradúzcalo o hable con alguien que lo entienda bien.

The data presented in this report are from the most recent testing done in accordance with administrative regulations in 401 KAR Chapter 8. As authorized and approved by EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data in this table, though representative, may be more than one year old. Unless otherwise noted, the report level is the highest level detected.

	Allowable Levels		Highest Single Measurement	Lowest Monthly %			Violation	Likely Source	
Turbidity (NTU) TT * Representative samples of filtered water	No more than 1 NTU* Less than 0.3 NTU in 95% of monthly samples		0.283	100			No	Soil runoff	
Regulated Contaminant Test Results									
Contaminant [code] (units)	MCL	MCLG	Report Level	Range of Detection			Date of Sample	Violation	Likely Source of Contamination
Radioactive Contaminants									
Combined radium (pCi/L)	5	0	1.1	1.1	to	1.1	Aug-14	No	Erosion of natural deposits
Inorganic Contaminants									
Asbestos (MFL)	7	7	0.102	0.102	to	0.102	June-11	No	Decay of asbestos cement water mains; erosion of natural deposits
Barium [1010] (ppm)	2	2	0.033	0.033	to	0.033	Nov-14	No	Drilling wastes; metal refineries; erosion of natural deposits
Copper [1022] (ppm) sites exceeding action level 0	AL = 1.3	1.3	0.067 (90 <sup>th</sup> percentile)	0.006	to	0.157	Aug-13	No	Corrosion of household plumbing systems
Fluoride [1025] (ppm)	4	4	0.994	0.968	to	0.994	Nov-14	No	Water additive which promotes strong teeth
Nitrate [1040] (ppm)	10	10	2.24	1.6	to	2.24	March-14	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfectants/Disinfection Byproducts and Precursors									
Total Organic Carbon (ppm) (measured as ppm, but reported as a ratio)	TT*	N/A	2.06 (lowest average)	1.26	to	3.67 (monthly ratios)	N/A	No	Naturally present in environment.
*Monthly ratio is the % TOC removal achieved to the % TOC removal required. Annual average of the monthly ratios must be 1.00 or greater for compliance.									
Chlorine (ppm)	MRDL = 4	MRDLG = 4	1.30 (highest average)	0.15	to	1.98	N/A	No	Water additive used to control microbes.
Chlorite (ppm)	1	0.8	0.630 (average)	0.15	to	0.70	Jan-14	No	Byproduct of drinking water disinfection.
Chlorine dioxide (ppb)	MRDL = 800	MRDLG = 800	470	0	to	470	April-14	No	Water additive used to control microbes.
HAA (ppb) Stage 2 [Haloacetic acids] (Individual Sites) Sebree	60	N/A	46 (Hiighest Location Average)	20	to	48 (range of individual sites)	N/A	No	Byproduct of drinking water disinfection
TTHM (ppb) Stage 2 [total trihalomethanes] (Individual Sites) Sebree	80	N/A	39 (Hiighest Location Average)	17	to	67 (range of individual sites)	N/A	No	Byproduct of drinking water disinfection.

In 2014 the City of Sebree Water Department received a Notice of Violation (NOV) from Kentucky Division of Water. We failed to take include all the information on the table to our 2013 Consumer Confidence Report (CCR). "The copper 90th percentile is missing from the table". There were no health effects due to this oversight. Remedial actions included detailing this violation in the 2014 CCR.